

## DAHANU THERMAL POWER STATION OCCUPATIONAL HEALTH & SAFETY PROCEDURE

**Annexure-21.04  
(DTPOHSP/15M04/21)**

### **SPECIAL TERMS & CONDITIONS OF CONTRACT IN RESPECT OF PPEs (SCOPE OF PPES AND OTHER SAFETY GADGETS)**

#### **General Purpose of PPEs**

Contractor shall compulsorily provide safety helmet and safety shoes to his each and every employee working in the plant at his cost (All the safety equipments should meet the specifications prescribed / approved by OH&S Dept.).

| <b>Sr. No.</b> | <b>Activity / Hazard</b>          | <b>Recommended PPEs</b>   | <b>Responsibility of providing PPEs Prime</b> | <b>Responsibility of providing PPEs Secondary</b> |
|----------------|-----------------------------------|---|---|---|
| 01             | Non toxic dust nuisance           | Dust mask<br>Panoramic goggles  | Contractor                                    | DTPS  |
| 02             | Toxic & corrosive liquids / gases | Hand gloves PVC / Rubber<br>Face Shield/ PVC Apron<br>PVC suit with hood<br>Positive Pressure Suit<br>Panoramic Goggles<br>Gum Boots/ SCBA Sets<br>Air line mask set<br>Cartridge type mask | Contractor                                    | DTPS  |
| 03             | Working at height                 | Safety Belt with double lifeline  | Contractor                                    | DTPS  |
| 04             | Material Handling                 | Canvas hand gloves<br>Leather Palm Canvas<br>Hand gloves<br>Leather hand gloves   | Contractor                                    | DTPS  |
| 05             | Hot material handling             | Heat resistance non asbestos hand gloves<br>Aluminised hand gloves<br>Aluminised suit with hood<br>Leather apron  | Contractor                                    | DTPS  |
| 06             | Grinding / Chipping               | Spectacle type toughed glass goggles<br>Panoramic goggles   | Contractor<br>Contractor                      | DTPS  |

In case returnable PPEs are not received back / received in damage condition beyond normal wear & tear, cost of PPE shall be deducted from the bills of Contractor concerned. Any situation, which is specific in above annexure decision of Engineer-in-charge in consultation with OH&S Dept. will be final.